

FDNP.MH60493 Drinking Water System Components

Page Bottom

Drinking Water System Components

See General Information for Drinking Water System Components

GODFREY & WING INC

220 CAMPUS DR AURORA, OH 44202-6663 USA MH60493

NSF/ANSI 61

Plant at: Aurora, OH

Joining and Sealing Materials

Trade Dsg	Water Contact Temp (°C)	Water Contact Mtl	Surface Area to Volume Ratio
Impregnation Resin			
Imprex 95-1000A (a)	82	-	80 sq. in/L
Imprex 95-1000AA	82	-	60
LL90T	82	-	60

Plant at: Houston, TX

Joining and Sealing Materials

Trade Dsg	Water Contact Temp (°C)	Water Contact Mtl	Surface Area to Volume Ratio
Imprex 95-1000A(a)	-	-	-

(a) - Certified for the wet vacuum process for brass materials having a porosity up to 12%. Certified for the dry vacuum process for brass materials having a porosity up to 2%.Certified for the wet vacuum process for brass materials having a porosity up to 12%. Certified for the dry vacuum process for brass materials having a porosity up to 12%.

Last Updated on 2018-03-15

Questions? Print this page Terms of Use Page Top
© 2018 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2018 UL LLC".